

PROFESSIONAL OUTDOOR LIGHTING

WARNING

WARNING: Risk of Electric Shock. Install power unit 5 feet (1.5m) or more from pool, spa or fountain.

WARNING: Risk of fire. If installation involves running wiring through a building structure, special wiring methods are needed. Consult a qualified electrician

DO NOT CONNECT TWO OR MORE POWER SUPPLIES IN PARALLEL

- 1. Do not connect the power unit to a 120V source controlled by a standard incandescent dimmer.
- 2. Wiring to connect the power unit to the luminaries shall be listed SPT-3, underground low energy circuit cable.
- Do not use an extension cord when connecting the power unit to the 120V source.
- Connect the power unit only to a covered 120V CLASS A GFCI receptacle marked "Wet Location" while in use.
- Internal convenience receptacle for use only with plug-in clock operated switch or control module rated minimum 125VAC, 15A - do not connect electric drill or other appliance.
- 6. For use only with UL Listed low voltage landscape luminaires and fittings connected where the sum of their wattages does not exceed the maximum power unit circuit wattage.
- The main secondary wiring is intended for shallow burial less than 6 inches (152mm).
- 8. Case must be grounded.
- 9. Power unit door to be kept closed and secure under normal operation.

SEE REVERSE FOR USE IN CANADA



WARNINGS FOR USE IN CANADA

CAUTION: FOR USE ONLY ON A BRANCH CIRCUIT PROTECTED BY A CLASS A TYPE GROUND FAULT INTERRUPTER.

TOTAL LAMP WATTAGE PER CIRCUIT FOR **ES150**: 150W

1. For use with landscape lighting systems only.

PROFESSIONAL

OUTDOOR LIGHTING

- The device is accepted as a component of a landscape lighting system where the suitability of the combination shall be determined by csa or local inspection authorities having jurisdiction.
- 3. Do not connect two or more power supplies in parallel.
- 4. Power supplies are for outdoor use only.
- 5. Do not mount power supply or luminaires within 3 m of a swimming pool or spa.
- 6. Risk of fire. Do not place insulation under terminal plate. Check connection after installation.

SAVE THESE INSTRUCTIONS